

A Review on Series Voltage Regulator for a Distribution Transformer to Compensate Voltage Sag and Swell

Vipin Gupta¹, Dr. Geetam Richhariya² Prof. Neeti Dugaya³ Dr. Manju Gupta⁴

¹M. Tech Scholar, Department of Electrical & Electronics Engg. OIST Bhopal (India)
Corresponding Author geetamrichhariya@gmail.com Department of Electrical & Electronics Engg. OIST Bhopal (India)

^{2,3,4}Associate Professor, Department of Electrical & Electronics Engg. OIST Bhopal (India)

Abstract: One of the most critical challenges facing the electricity grid is meeting the power quality (PQ) standard. Power quality issues, such as voltage dips and spikes, are most common in low-voltage distribution systems and during transmission. One of the most common approaches of compensating for voltage sag and swell is to use a series voltage regulator for a distribution transformer, which deals with power quality concerns in the electrical power distribution system. This review paper discusses about the DSMPI Controller based Series Voltage Regulator for a Distribution Transformer to Compensate Voltage Sag/Swell.

Keywords: single-phase AC; sag and swell conditions; PI and DSM-PI controllers; harmonics; THD; MATLAB Simulink software.

I. INTRODUCTION

For distributors, power quality is a critical concern. They're responsible for ensuring that consumers always have access to reliable power while meeting strict quality standards. A number of government agencies have a hand in this debate as well. Power quality is governed by European standards and, often, national norms. The voltage requirement is one example. It must be maintained inside the

predicted bounds. In order to accomplish this goal, distribution network providers should use the most effective technique possible given the available technologies.[1]

The typical distribution transformer may be cheap, efficient, and dependable, but it cannot ensure the safety of loads against transients such voltage drops and spikes. Many industrial customers in power distribution networks now see voltage dips and spikes as one of the most serious problems with power quality.[2] As electronics in industrial applications get more sophisticated, customers' loads are becoming more sensitive to voltage disturbances like sags and swells.

“Voltage sags and swells can be described by two essential characteristics: magnitude and duration.”

The Power Quality (PQ) indicates how closely the actual power supply matches the theoretical power supply.

1. If power quality (PQ) is high, then all loads on the power grid function normally and at peak efficiency.
2. When power quality (PQ) is low, any load added to the network can shorten the life of the equipment or negatively impact its performance.

Electric power is analysed to address PQ difficulties and establish the optimal compensating strategy in order to mitigate the repercussions of inadequate PQ and enhance the utility's performance.[4]

A. Power Quality Problems

The "continuity" of supply and the "quality" of voltage best describe the reliability of the electricity supplied. Specifically, IEEE standard 1100 defines power quality as

"The idea of controlling and establishing the touchy supplies in a manner that is suitable for the operation of the gear."

Power quality Problems: The reliability of our electrical supply may be compromised in a number of ways. These kinds of disruptions are almost inevitable with the electricity grid's interconnected infrastructure. Therefore, proper care must be made to keep the appropriate equipment running in order to avoid the repercussions of these issues and preserve the quality of the power supply. A variety of power quality issues, along with their origins and effects, are discussed here.

Interruptions

An interruption in supply that lasts over an extended amount of time. In this case, the voltage or current supply signal may be negligible. This is defined as "lower than 10% of the stated value" by the IEEE (IEEE Std. 1159:1995) and as "lower than 1% of the declared value" by the IEC (International Electro technical Committee). These are divided into two categories according on the length of the disruption:

Short Interruption:

"If the duration for which the interruption occurs is of few milli seconds then it is called as short interruption"

Causes: The causes of these interruptions are-

- "Opening of an Automatic Re-closure
- Lightening stroke or Insulation Flash over"

Consequences:

- There is an impact on the database storage system.
- Problems with delicate machinery like PLCs and ASDs are possible.

Long Interruptions:

An interruption is considered significant if it lasts for more than a few milliseconds but less than several seconds.

Causes: The causes of these interruptions are-

- "Faults in power system network
- Human error
- Improper functioning of protective equipment"

Consequences: In the event of this kind of disruption, electricity will be fully cut off until the issue is repaired.

Waveform Distortion

Whenever possible, sinusoidal voltage and current signals are produced and sent over the electrical grid. Yet the signal loses its sinusoidal character and exhibits aberrations. Causes of distorted waveforms include:

- **DC Offset:** DC offset refers to the DC voltage that is already present in the signal. Whenever a DC offset is present, the signal deviates from its true reference level by a certain amount.

- **Harmonics:** Integral multiples of the fundamental frequency are represented by voltage and current signals. These occur when non-linear loads are connected to the electricity grid.

- **Inter Harmonics:** These are harmonics that occur at non-integer multiples of the fundamental frequency.

- **Notching:** The commutation of a power electronic equipment causes this periodic disruption as current flows from one phase to the next.

- **Noise:** Unwanted signals are to responsible for this. The interference of several networks in the transmission of information results in the creation of noise.

Frequency Variations

The frequency at which the electrical grid is intended to function is 50 hertz (Hz). The pace at which the framework's generators spin determines the frequency of the system as a whole. If there is a mismatch between supply and demand, the frequency will fluctuate as a result. When a generator fails or loads are switched on and off quickly, it causes significant frequency fluctuations.

Transients

Transients are the short-lived fluctuations in the voltage and current signals used by the electrical grid. These fluctuations are split into two classes: impulsive and oscillatory. Unidirectional impulsive

transients' contrast with the fast reversals in polarity seen in oscillatory transients.

Causes: There are a number of different factors that might lead to transients in the electricity grid. The are-

- “Arcing between the contacts of the switches
- Sudden switching of loads
- Poor or loose connections
- Lightning strokes”

Consequences:

- Devices that rely on electronics are impacted and may display inaccurate information.
- The temperature within the motors rises as they work.
- Ballasts in fluorescent lights failing;
- Decreased equipment efficiency and lifespan

Voltage Sag

When the voltage drops by 10% to 90% for a half cycle or longer, this is known as a voltage sag. Figure displays the voltage signal with a drop.




Figure 1: Voltage sag

Causes: The causes of voltage sag are-

- High current consumption during motor starting.
- Difficulties with the electricity grid

- An unexpected rise in the system's load

Consequences:

- Failure of contactors and switchgear
- Malfunction of Adjustable Speed Drives (ASD's)

Voltage Swell

A voltage swell occurs when the voltage increases by 10% to 80% over the typical value for a half cycle or longer. Fig. displays the voltage signal during an increase.




Figure 2: Voltage swell

Causes:

- Disconnection of major load
- Capacitor bank activation
- Electrical electricity being cut off suddenly
- Phases with no grounding undergo a shift in ground reference

Causes:

- Disconnection of major load
- Capacitor bank activation
- Electrical electricity being cut off suddenly
- Phases with no grounding undergo a shift in ground reference

Voltage Unbalance

When voltage signals from distinct phases have unequal magnitudes and phase angles, this is known as voltage imbalance.

Causes:

- Existence of significant single-phase loads
- Defects can show up in the system

Consequences:

- Harmonics are present.
- Loss of system efficiency
- The power loss has increased
- Equipment lifespan is shortened.

B. Power Quality Issues in Distribution Grid

Although conventional distribution transformers are relatively durable and reliable depending on their need, there is no guarantee that they will protect loads from annoyances like poor grid voltage regulation under load, poor performance under voltage disturbances (sag/swells/distortion), and sensitivity to harmonics. [30]

Increasingly, both the power company and its consumers are worried about power quality concerns. Despite the utility industry's best efforts and extensive expenditures, supply system instabilities will continue to occur. Poor power quality occurs due to the ageing distribution grid infrastructure and the incompatibility of current load characteristics with the electric power supply environment. Substantial economic losses in several sectors are a direct effect of this.

A. Sag Detection Techniques

A voltage sag detection method can identify the onset, termination, duration, magnitude, and phase shift of a voltage sag. Typical methods for identifying voltage drops are as follows.

A. Peak value method: The peak, or amplitude, of the supply voltage may be monitored and compared to a standard to determine the health of the supply. A controller might be programmed to activate the inverter if the difference is larger than a certain threshold.

B. Root Mean Square (rms) method: When V_{rms} first falls below 0.9pu, the sag is said to have started. You may determine when the sag will finish by looking for a period in which V_{rms} is consistently below 0.9pu for at least half a cycle. The beginning of this range is set as the recovery time. [34]

C. Fourier Transform (FT): The FT is achieved by orthogonal decomposition of the signal from the power supply. In most cases, we use a collection of functions that is trigonometrically or exponentially orthogonal. The amplitude and phase of the supply waveform's frequency components may be determined by applying FT to each phase of the supply. For practical digital implementation, "Windowed Fast Fourier Transform (WFFT)," is readily adaptable to real-time control system environments. The only drawback is that, since FT uses an averaging technique, accurate information regarding the sag depth and its phase takes at least one full cycle to generate.

D. Space Vector Method: The magnitude and direction of the three-phase voltages

V_{abc} are converted to the two-dimensional voltage V_{dq} . Indicators indicating the occurrence of an event include any change in any quantity. Quantifying the disruption in the dq-frame that necessitated the transformation back to the abc frame may be done by comparing these values to reference values. This process is instantaneous but needs a sophisticated controller.

B. Overcoming Power Disturbances Challenges

A method of monitoring and analysis is essential for finding solutions to these problems and decreasing their occurrence rates. "Guidelines for handling such situations are outlined in the newly released IEEE 1668 standard Recommended Practice for Voltage Sag and Short Interruption Ride-Through Testing for End-Use Electrical Equipment Rated Less than 1000V." The data may then be translated into an understandable format and shown in simple graphs using software like Sapphire. Using this programme in tandem with a power quality metre or power quality analyzer allows for a comprehensive log of voltage drops, spikes, and other power anomalies to be compiled. [35]

Without manually setting triggers or thresholds, a power quality analyzer that records in real time will be able to record almost every event that occurs on your network. With this sophisticated analyzer, you can easily install it and link the event to a given condition to determine its root cause. The stability and dependability of your system or equipment will increase automatically if you define sag magnitudes and durations that should not result in

equipment failure, for example, and if you can determine the severity of the sag history on the facility.

II. LITERATURE REVIEW

(Carreno et al., 2021) [1] There is a lot of strain on distribution systems because of the wide range of possible operating circumstances, which puts distribution transformers and lines at risk and reduces the quality of service provided to customers. The quality of service may be impacted when fluctuating loads cause voltage profiles to go beyond the ranges specified by grid regulations. On the other hand, nonlinear loads like diode bridge rectifiers without power factor correction devices provide nonlinear currents that disrupt the distribution transformer's functioning and shorten its lifespan. The unpredictable use of household appliances is a major cause of variable loads at residential levels; nevertheless, electric car charging stations have lately contributed to this phenomenon as well. As a result, the distribution transformer cannot function reliably under such situations, necessitating the use of backup infrastructure. Hybrid transformers, which combine the functions of a traditional transformer with a power converter, are one promising approach to addressing a variety of power quality issues. For anyone interested in learning more about hybrid distribution transformers, this article serves as a literature overview.

(Qureshi, 2020) [2] The quality of the electricity supplied to them is a major factor influencing the performance of modern technological gadgets. Power quality issues, such as non-sinusoidal

voltage and frequency of current, are common and occur often, causing failure of end-use equipment. Voltage fluctuations during drops and spikes are the primary issue. Custom power devices may be utilised to solve these problems. These issues are solvable, at least to some degree. Ideally, power grids provide consumers with a steady stream of energy that exhibits sinusoidal voltage of narrow magnitude and frequency. In comparison to small and medium enterprise systems and uninterruptible power supplies, DVRs have a greater capacity for power. When compared to the DSTATCOM and other bespoke power devices, the DVR is more compact and affordable. The DVR is quick, adaptable, and effective. DVR has the additional feature of correcting for harmonics in addition to compensating for power dips and surges. When abnormal conditions arise in the distribution system, voltage sag/swell and power quality issues are eliminated or at least lessened thanks to DVR.

(Tajne, 2020) [3] Most distribution systems' primary worry is a voltage issue related to power quality. Thus far, the under-voltage (voltage sag) situation brought on by a short circuit or fault has been the primary source of the voltage issue. Today, power quality in the distribution system is the most pressing concern for all types of modern infrastructure. Under-voltage (voltage sag) conditions induced by short circuits or faults in the distribution system are often thought to be the root of the voltage issue. In this study, a series voltage regulator for distribution transformers is introduced to address the problem of voltage drop/rise on the secondary side of the transformer.

The secondary side of a transformer is connected to a series voltage regulator based on hysteresis. Gating signal production is handled by the hysteresis controller, whereas reference voltage generation is handled by the Phase lock loop. Every part of the system is created in MATLAB. In order to enhance power quality disturbances, the system is tested under a variety of conditions.

(Dandoussou & Kamta, 2020) [4] The study's goal is to analyse clearly by identifying and describing each disturbance. The primary goals are to examine the causes of unexpected faults on wires that provide loads and to conduct a survey of the adverse effects resulting from the load, in particular typical loads utilised in industrial settings. The effects of these disruptions on a Distribution Line network were analyzed through simulation, and the findings were given.

(KARAMAN et al., 2020) [5] With each passing day, the issue of poor electricity quality becomes more pressing. The primary elements affecting power quality are harmonic current and reactive power. Harmonic current and reactive power are used by the induction motors from the mains supply. Transmission line efficiency and heat loss are both negatively impacted by reactive power and harmonic current. These issues have been addressed using passive and active filter applications. Passive filters have a few limitations. Examples of these limitations are the system's large physical size and its resonance with load. Since Active Power Filters (APFs) may be used in conjunction with harmonic and reactive power compensation as suitable control

approaches, their potential application domains are expanding quickly. Using a three-phase Parallel Active Power Filter, this research suggests simulating the process of power factor correction and reactive power compensation for a three-phase induction motor in MATLAB/Simulink. The "Sine Multiplication Technique (SMT)" is used to produce the reference currents used by PAPF. We show simulation experiments to evaluate the motor's functionality in a variety of real-world circumstances. "Using a hysteresis controller-based PAPF filter, the reactive power of a three-phase induction motor may be compensated, bringing the power factor up to 1."

(Wang & Cao, 2019) [6] Power Line Communications (PLC) have a significant challenge from impedance mismatch, which reduces signal power transfer and may disrupt transmissions. Power line modems and power line networks have an inherent impedance mismatch; however, this may be efficiently compensated for by using impedance matching methods tailored to a particular frequency or frequency range. In this research, we explore the complexities involved in finding the right balance between competing goals in impedance-matching network design. We also present a helpful taxonomy of the many existing state-of-the-art PLC impedance matching approaches and conduct a thorough examination of their respective histories. We conclude with a discussion of key problems (concerns) and recommendations for future study that warrants more investigation. In order to develop an efficient impedance matching coupler for PLC applications, this paper offers a

helpful reference for researchers and manufacturers to rapidly comprehend impedance matching concepts.

(Hren & Mihalič, 2018) [7] Total Harmonic Distortion (THD) and DC link usage are two important factors to keep in mind while designing a single-phase inverter system (grid-connected, UPS, or motor drive). When the DC voltage is lowered, the output voltage may be maintained within a specific range by using over-modulation. Higher-order harmonics (especially the third), which are connected to the fundamental frequency, have a negative impact on the inverter's output voltage. In this study, we conduct a comprehensive examination of a single-phase inverter in the over-modulation domain, dissecting its performance at each of its three possible output voltage levels. According to the results of a frequency spectrum analysis, the third harmonic component in the output voltage is almost cancelled out by the third harmonic component in the modulator.

(Sur et al., 2018) [8] The Reduction of Transmission-System Harmonics is the subject of this paper. Since harmonic frequencies are a common source of power quality issues, this study focuses on methods for removing harmonic content from the system using a variety of Active and passive Filter configurations, each of which is managed by an Active Damper Controller. The non-linear load is the primary generator of harmonics since it uses discontinuous current and injects harmonics, both of which result in transmission losses. The simulation work is also carried out in MATLAB to evaluate the outcome without or with hybrid filter,

demonstrating that the active damper may become a potential solution to stabilize the future power electronics-based power systems.

(Naderi et al., 2018) [9] Due to the increasing sensitivity of loads and the proliferation of nonlinear loads in the electrical distribution network, it is obvious that power quality has become a crucial component of contemporary systems. The dispersed nature of harmonic loads makes distributed power quality improvement (PQI) a necessity when trying to manage them. Years of research have gone into developing various filters and devices to enhance power quality, but the nature of the distribution system has changed, making power electronic based DGs more important than ever. In this research, we analyse the supplementary services of flexible DGs and perform a thorough literature assessment of power quality enhancement devices. The literature on the concept of microgrids, testbeds, and associated control approaches is also reviewed. In spite of the fact that DGs were used in several PQI-related contexts, these usages did not constitute the defining characteristics of multi-functional DGs. Several strategies of control are examined and classified based on their treatment in the academic literature. Finally, a few detailed comparisons are made between the various methods, taking into account their nature, capabilities, benefits, and implementation costs.

(Senapati et al., 2018) [10] Power quality in a grid-connected PV-battery-fuel-cell hybrid energy system is improved in this research by exploring the usage of a shunt

active filter. To control the shunt active filter, we use a variation on the Sinusoidal Current Control Strategy. A shunt active power filter is included to lessen the load imposed by the harmonic current component and compensate for the imaginary or reactive power produced by the precise and careless functioning of the hybrid system. Using a method of sinusoidal current management, the source of the current may be recovered. To evaluate the performance of a sinusoidal current control method for a shunt active power filter in a passive load situation with a non-linear load, we use MATLAB R2016a. Through MATLAB simulation, we confirmed the power filter system's capacity to mitigate harmonics, and we validated the control strategy. Total harmonic distortion (THD) of voltage and current proves whether or not a controller designed for ShAPF can successfully provide harmonic isolation of passive loads.

(Singh et al., 2018) [11] In recent years, shunt active power filters (SAPFs) have become an established cutting-edge technology for resolving issues associated with current harmonics and reactive power compensation. In this work, we provide a technical overview of several SAPF control techniques. Several control techniques, such as the construction of switching patterns for a voltage source inverter, the management of dc link voltage, and the formation of reference current in the time domain, frequency domain, and via soft computing, have been investigated. The purpose of this work is to offer a comprehensive introduction to SAPFs for use in a wide range of scientific and technical disciplines.

(Tareen & Mekhief, 2018) [12] Nonlinear loads, current harmonics, and power quality issues are all easily remedied by a shunt active power filter. There are drawbacks to using APF topologies for harmonic correction since they need a large number of components with a high power rating. With the use of low-power rating APFs and passive filters, hybrid topologies are used to reduce the voltage source inverter's power rating. Many passive components are packed inside the transformer in "hybrid APF topologies for high-power rated systems." In this study, we suggest a new "VSI topology for a three-phase SAPF" with four switches and two legs, which may significantly cut down on both the system's price and its footprint. "A two-arm bridge structure, four switches, coupling inductors, and LC PF sets make up the suggested topology." When the set of power switching devices is removed, the third leg of the three-phase VSI is also gone, and the phase is instead connected straight to the negative terminals of the dc-link capacitor. When compared to traditional APF topologies, the suggested topology improves the capacity of harmonic correction and enables full reactive power compensation. The new experimental prototype is subjected to extensive laboratory testing in line with the IEEE-519 standard to validate the results with respect to total harmonic distortion, balanced supply current, and harmonic compensation.

(Madhu et al., 2018) [13] Total harmonic distortion must be kept below the threshold for unacceptable levels in order to comply with power quality standards (IEEE-519). The shunt active power filter is the primary focus of this research

because of its popularity in the field of harmonic removal. The load current has been continually monitored, and the active power filter has continuously adjusted to the shifting harmonics of the load. This study describes the operation and efficiency of a PI and Hysteresis current controller based on the instantaneous power theory applied to a three-phase shunt active power filter.

(K.V.PRADEEP KUMAR REDDY, 2018) [14] One of the most critical challenges facing the electricity grid is meeting the power quality (PQ) standard. Voltage dips and surges in low-voltage distribution systems, as well as transmission-side issues caused by power-hungry appliances, are among the most common issues with electrical current quality. When dealing with power quality issues in the electrical grid, one of the most prevalent methods for mitigating voltage sag and swell is the installation of a series voltage regulator on a distribution transformer. An automated secondary connection power electronic converter is attached to a line frequency transformer in the proposed configuration. Automation of this connection is achieved by the use of a high- or medium-frequency transformer.

(Devadasu, 2017) [15] Voltage fluctuations, power surges, and other types of poor power quality may have a negative impact on the efficiency of the power grid. Nowadays, power engineers handle voltage sag and swell to lessen power quality difficulties. Even a little shift in voltage may have a significant impact on the efficiency of the power grid and the performance of any associated loads. In this work, we show how to use FFT

analysis to spot a voltage dip or spike. The study also includes the DVR-implemented solutions to the identified voltage sag and swell problems. DVR is controlled by the straightforward d-q theory, which generates the necessary reference signals and gate pulses for the DVR's switches. Through the use of MATLAB/SIMULINK, we were able to model the suggested idea and show the resulting findings for detection and prevention. It was shown how to use FFT analysis to detect voltage sags and swells throughout the power system network at various stages. In addition, the findings demonstrated that voltage sag and swell may be reduced using DVR.

(Biricik et al., 2016) [16] Low ratio “shunt active power filters (SAPFs)” may perform current harmonic cancellation and provide unity power factors in the presence of undistorted and balanced grid voltages. When source voltages are erratic and imbalanced, however, this is impossible. This research presents the “hybrid active power filter (HAPF)” topology, which is an efficient and low-cost method of meeting the needs of industries in terms of harmonic current suppression and non-active power compensation. The integration of power capacitors and LC filters with the shunt active power filter (APF) is studied using an efficient method. Using instantaneous reactive power theory and a self-tuning filter algorithm, a novel approach is given for mitigating the detrimental consequences of a less-than-ideal grid voltage. An FPGA architecture was created with the help of the OPAL-RT system to allow for real-time control of the investigated system. The tested and shown

performance result of the proposed HAPF system.

(Ali et al., 2016) [17] Power electronic converters and the power electronic loads they connect to the distributed power plants are a source of harmonics and reactive power, which degrade the operation of the power system network. Activated filters, sometimes called active power line conditioners, are a novel kind of switching compensator that were developed to address the shortcomings of passive LC filters. These active filters can wipe out interference from a wide variety of harmonic orders, can withstand resonance between the filter and the network's impedance, and can be built to a small size. The focus of this research is on developing a shunt active filter with a controller based on many theories to compensate for harmonics and reactive power in unbalanced and distorted systems.

(Meenakshi et al., 2015) [18] Using a constant frequency variable speed wind turbine, this research implements the SVPWM switching mechanism. For a "doubly-fed induction generator," MATLAB/Simulink is used for modelling and simulation. We have measured the overall harmonic distortion of this wind electric generator at several settings of stator current, rotor speed, and electromagnetic torque. When compared to other pulse width modulation methods, this one reduces distortion to a greater extent.

(Sandeep, 2014) [19] The increasing complexity of modern life has resulted in a corresponding rise in the need for electricity. Many common household appliances can't function without constant

access to reliable electricity. There is a direct correlation between the power quality and the performance of the user's equipment. However, several internal and external variables influence the final product in terms of power quality. They include things like voltage and frequency fluctuations, malfunctions, outages, and so forth. Both the lifespan and performance of the apparatus are shortened by the poor power quality. As a result, these issues need to be addressed in order to improve the system's overall performance and the functionality of the consumer devices it supports. The existence of harmonics is the primary effect of these issues. Damage to the machinery occurs as a result of overheating, insulation breakdown, induction motors running too fast, etc. Filtering out these harmonics is the key to solving these issues. Numerous filter topologies exist in the literature for this function.

(Kumar et al., 2014) [20] With the advent of more complex gadgets, whose efficiency is highly dependent on the reliability of their power source, power quality has become an increasingly pressing issue in the modern day. Many electronic equipment, such as programmable logic controllers and variable speed drives, lie at the heart of today's manufacturing processes. Due to the increased sensitivity of electronic equipment, industrial loads have reduced tolerance for power quality issues such as voltage dips, voltage spikes, and harmonics.

(Kaur & Gupta, 2014) [21] This study discusses using dynamic voltage restorers (DVR) in power distribution systems to prevent voltage drops or spikes at vital

loads. DVR is an example of a specialized power gadget that may be used to offset other forms of losses. The controls for DVR were modelled and simulated in MATLAB, demonstrating the adaptability and simplicity of the MATLAB platform for research into and comprehension of such compensatory mechanisms. The performances of DVR in maintaining load voltages during voltage sags/swells are shown and explained through simulation results.

(Islam et al., 2013) [22] The inverter is the single most critical piece of equipment for effectively harnessing renewable energy. The simulation results for each Op-Amp circuit are shown in sequence. Standalone loads and high voltage sensitive loads/systems, such as micro-grid systems and big industrial machines, are emulated using this analog circuit (Op-Amp) controlled voltage source inverter with and without transformer. Both the original simulation results and the results after applying a passive filter to reduce harmonics are shown. In addition, two popular inverter-based micro grid system architectures are shown in the paper: one with a shared DC bus and the other with an AC bus.

(Sandhya, 2013) [23] A power quality (PQ) issue is defined by voltage and/or current variations from the ideal sine wave. Voltage dips and spikes, as well as harmonic currents, are common causes of P-Q imbalances. There has been a rise in interest in Custom Power (CP) technologies that improve power quality in recent decades. One kind of CP gadgets, known as a “Unified Power Quality

Conditioner (UPQC),” may fix both load current and supply voltage issues at once.

III. TRANSFORMERS

Basics of Transformers

A transformer is an electrical tool used to transfer energy by electromagnetic induction from one circuit to another. There is no frequency shift during the power transmission because of the attendant. The state power transformer is used to symbolize transformers with an output power of 500 kilovolt amperes (KVA) or more in an electrical network and to show numerous AC supplies from the public electricity supply at varying voltages and ampere ratings.

This kind of transformer is used in distribution systems to convert between lower and higher voltages. Normal power transformers are fluid immersed devices with a 30-year lifespan. Based on their output voltage and current ratings, power transformers fall into one of three categories. There are three different sizes of power transformers: big, medium, and small.

- “The range of large power transformers can be from 100MVA and beyond
- The range of medium power transformers can be from - 100MVA
- The range of low power transformers can be from 500-7500kVA”

These transformers are used for the transmission of electricity. The high-current, low-voltage circuit is maintained

on one side of the transformer, while the low-voltage, high-current circuit is maintained on the other side. In order to generate electricity, a power transformer uses Faraday's induction law. It breaks out the electrical grid into zones, detailing how each component of the system was built to function at the rates determined by the power transformer.[25]

Types of transformers

Step up Transformer & Step-down Transformer - They are used in the transmission and distribution of electrical power to increase or decrease the voltage of the current.

Three Phase Transformer & Single-Phase Transformer - The former is often preferred in a three-phase power system because to its lower overall cost. However, a bank of three single-phase transformers is preferred than a single three-phase transformer when space is at a premium.

Electrical Power Transformer, Distribution Transformer - Power transformers are used to transmit electricity from one high-voltage system to another, such as from a power plant to the transmission and distribution networks. Their application in the transmission network extends to voltage boosting and lowering. It is most effective while running at or near full load, which is when it is used most often. In order to distribute electricity to homes and businesses, a distribution transformer reduces the voltage. It has excellent voltage control and can run at optimum efficiency for 24 hours a day, 50% of the time.

Indoor Transformer & Outdoor Transformer - Indoor transformers are

those whose primary function is to be installed inside a building, whereas outdoor transformers are those whose primary function is to be installed outside.

Oil Cooled & Dry Type Transformer - Transformer oil is used as the cooling medium in oil-cooled transformers, whereas air is used in dry-type transformers.

Phase-Shifting Transformer- An important component of any sophisticated power transmission network is the phase-shifting transformer, which allows for fine-grained regulation of power distribution along individual circuits. Phase-shifting transformers' uses:

- a) To regulate the transfer of energy between two huge, separate power grids;
- b) To regulate the amount of usable active power in a transmission line by altering the effective phase displacement between the input voltage and the output voltage.

Distribution Transformers

The concept of a distribution transformer, a common kind of isolation transformer, is also presented. This transformer's primary use is in transforming very high voltage into more manageable levels, such as 240 or 120 volts, for use in power grids. Single-phase and three-phase transformers, pad-mounted transformers, underground transformers, and distribution transformers installed on poles are only some of the options in the distribution system.[27]

Service transformer is another name for a distribution equipment. The last voltage transformer in the electricity grid, it

reduces the output used in the distribution lines to the users' rating.

Therefore, a constant supply of high-quality power is essential for a smart grid. The distribution transformer, seen in Figure, is an important component of the system for delivering clean power to the final user, whether it a business, factory, or home.




Figure 3: Concept of Functionality of Distribution Transformers in Electric Grid

Distribution transformers may be found in a wide range of sizes and efficiencies to accommodate a wide variety of applications and end-user budgets. There are a number of different transformer types used in the distribution system, all of which include secondary terminals that provide electricity to the end user at a usage voltage level. One common kind of distribution transformer used in the USA to power single-phase appliances is the single-phase distribution transformer.

There must be a single kind of pole-mounted transformer for the single-phase residential load. There was a total of three secondary terminals on this pole-mounted distribution transformer design. There are three total terminals: two for the phases and one for ground. Voltage is 240 volts

between phases when using two-wire systems, and 120 volts between phases and ground. Therefore, depending on their needs, consumers may get either 240 volts or 120 volts.

Some important properties of a distribution transformer are stated as:

- Minimal in size
- Used as a step-down transformer with input voltages as low as 33 kilovolts (kV).
- Consistently handles between 60% and 70% of its rated capacity throughout the day
- Requires only 3-5 volts and a standard wall outlet to charge

It is the kind of distribution transformer being used that determines how this instrument is wired. Single-phase transformers may have either one or two bushings, and are often configured in a wye. Only in the right configuration can these major sections be used with three-wire or four-wire wye connections.[28]

Additionally, these transformers may be connected to the overhead wires in two different ways, namely:

Wye: To do this, a transformer that converts phases to ground is used. The intersection between the two stages may be found at the top of the structure. Another part of the winding is grounded by its connection to the neutral line. Due to the possibility of ground-directed currents in the neutral section, a wye design is used when unstable powers must be connected. Unstable powers cause voltage changes on the three-phase wires when in the delta connection.

Delta: In this case, a transformer of the phase-to-phase kind is used. It features a two-phase connection between its two bushings. Another part of the winding is grounded by its connection to the neutral line. This setup has one major drawback: if one of the main phases goes into a de-energy condition, the other phase will cause current to flow in the other way, which might be dangerous for the workers and staff.

Some applications of the distribution transformer are as the following:[29]

This transformer is used in commercial and residential settings, and its output voltage ranges from high to low.

The major function of this is to provide isolation between two windings (primary and secondary) by reducing the input power.

Power plants generate electricity, and this transformer sends it to far-flung areas.

Electricity is often sent via a distribution transformer to businesses with use below 33KV and homes with usage between 440V and 220V.

IV. PROPOSED METHODOLOGY

Power quality problems, such as voltage sag and swell, primarily impact the distribution system. Voltage drops happen because of things like short circuits, lightning strikes, faults, and inrush currents. Voltage surges may be caused by a number of factors, including the starting and stopping of large loads, inadequately sized power supplies, poorly controlled transformers, and a single line to ground fault on the system. "Generation, transmission, and distribution are the three

main components of the electric power system." Existing LFT is connected to an auto-connected PEs module on the secondary side to smooth out voltage dips and spikes; this is the suggested solution. As a result of this autoconnection, a compensator with a shunt input and series output may be constructed, with no capacitive energy storage required. Thus, the suggested system is distinct from the typical series compensator, such as a DVR, in both its structure and its operation.

To control the device such that desired performance is obtained and to decrease the THD by mitigating the problem of distorted voltage due to sags, swell or harmonics, a comparative analysis is carried out with PI and DSM-PI controllers for the generation of output voltage.

V. CONCLUSION

There is a growing problem in the industrial sector and among consumers due to the increased demand for reliable power. Among them, voltage imbalance is regarded as the most significant factor that reduces the efficiency of electrical devices. This research proposes a series voltage regulator and control system for use in a distribution transformer to smooth out voltage dips and spikes. The suggested method may be readily included into ordinary distribution transformers to provide sag or swell correction to an existing distribution grid.

As a result, the suggested system represents a potential retrofit for current distribution transformers to enhance power quality in the future grid, particularly in light of the growth of renewable and distributed energy sources. The power

quality may be improved and renewable energy sources can be expanded in the future by integrating the suggested scheme with the current distribution grid system.

References

- [1] A. Patel, "Electrical Power Engineering and Mechatronics The Impact Analysis Of Motors Current Gain On High Frequency Harmonics Fed From Inverter," 2021.
- [2] A. Carreno, M. Perez, C. Baier, A. Huang, S. Rajendran, and M. Malinowski, "Configurations, power topologies and applications of hybrid distribution transformers," *Energies*, vol. 14, no. 5, pp. 1–35, 2021, doi: 10.3390/en14051215.
- [3] A. Qureshi, "Analysis of DVR in Distribution during Voltage Sags & Voltage Swells Analysis of DVR in Distribution during Voltage Sags & Voltage Swells Submitted in partial fulfillment of the requirement for the award of Degree of Master of Technology in Power System .," no. March, 2020.
- [4] D. Tajne, "Voltage Sag And Swell Compensator For Distribution Transformer Using Series Voltage Regulator," vol. 8, no. 5, pp. 3459–3465, 2020.
- [5] A. Dandoussou and M. Kamta, "Journal of electrical engineering and electronics technology Analysis of Electrical Power Disturbances in Distribution and," vol. 9, no. September, pp. 4–11, 2020, doi: 10.37532/jeet.2020.9(4)e.176.
- [6] Ö. A. KARAMAN, A. GÜNDOĞDU, and M. CEBECİ, "Performing reactive power compensation of three-phase induction motor by using parallel active power filter," *Int. Adv. Res. Eng. J.*, vol. 4, no. 3, pp. 239–248, 2020, doi: 10.35860/iarej.731187.
- [7] B. Wang and Z. Cao, "A review of impedance matching techniques in power line communications," *Electron.*, vol. 8, no. 9, pp. 1–25, 2019, doi: 10.3390/electronics8091022.
- [8] A. Hren and F. Mihalič, "An improved SPWM-based control with over-modulation strategy of the third harmonic elimination for a single-phase inverter," *Energies*, vol. 11, no. 4, 2018, doi: 10.3390/en11040881.
- [9] K. Sur, B. Dhabale, and N. Khobragade, "Performance Analysis of a Hybrid Filter Composed of Passive and Active Filter with Active Damper Controller," vol. 4, no. 3, pp. 32–38, 2018.
- [10] Y. Naderi, S. H. Hosseini, S. Ghassem Zadeh, B. Mohammadi-Ivatloo, J. C. Vasquez, and J. M. Guerrero, "An overview of power quality enhancement techniques applied to distributed generation in electrical distribution networks," *Renew. Sustain. Energy Rev.*, vol. 93, pp. 201–214, 2018, doi: 10.1016/j.rser.2018.05.013.
- [12] H. Singh, M. Kour, D. V. Thanki, and P. Kumar, "A review on Shunt active power filter control strategies," *Int. J. Eng. Technol.*, vol. 7, no. 4, pp. 121–125, 2018, doi: 10.14419/ijet.v7i4.5.20026.
- [13] W. U. K. Tareen and S. Mekhief, "Three-Phase Transformerless Shunt Active Power Filter with Reduced Switch Count for Harmonic Compensation in

- Grid-Connected Applications,” IEEE Trans. Power Electron., vol. 33, no. 6, pp. 4868–4881, 2018, doi: 10.1109/TPEL.2017.2728602.
- [14] B. R. Madhu, M. N. Dinesh, and B. M. Ravitheja, “Design of shunt hybrid active power filter to reduce harmonics on AC side due to non-linear loads,” Int. J. Power Electron. Drive Syst., vol. 9, no. 4, pp. 1926–1936, 2018, doi: 10.11591/ijpeds.v9n4.pp1926-1936.
- [15] D. S. M. K.V.PRADEEP KUMAR REDDY, “MITIGATING OF VOLTAGE SAG / SWELL BY SERIES VOLTAGE REGULATOR FOR A DISTRIBUTION,” vol. 5, no. 4, pp. 69–73, 2018.
- [16] G. Devadasu, “Voltage Sag and Swell Identification Using FFT Analysis and Mitigation with DVR,” IOSR J. Electr. Electron. Eng., vol. 12, no. 2, pp. 30–40, 2017, doi: 10.9790/1676-1202013040.
- [17] S. Biricik, O. C. Ozerdem, S. Redif, and M. S. Dincer, “New hybrid active power filter for harmonic current suppression and reactive power compensation,” Int. J. Electron., vol. 103, no. 8, pp. 1397–1414, 2016, doi: 10.1080/00207217.2015.1116113.
- [18] I. Ali, V. Sharma, and P. Chhawchharia, “Control Techniques for Active Power Filter for Harmonic Elimination & Power Quality Improvement,” Int. J. Electr. Electron. Data Commun., vol. 4, no. 10, pp. 25–36, 2016.
- [19] V. Meenakshi, G. D. Anbarasi Jebaselvi, and S. Paramasivam, “Space vector modulation technique applied to doubly fed induction generator,” Indian J. Sci. Technol., vol. 8, no. 33, 2015, doi: 10.17485/ijst/2015/v8i33/60766.
- [20] A. Ponder, S. Member, I. L. Pham, and S. Member, “Space Vector Pulse Width Modulation in Wind Turbines ’ Generator Control,” IEEE Res. Pap., pp. 1–6, 2014.
- [21] A. Sandeep, “STUDY OF HYBRID ACTIVE POWER FILTER FOR POWER QUALITY IMPROVEMENT Master of Technology STUDY OF HYBRID ACTIVE POWER FILTER FOR POWER QUALITY Master of Technology,” Dep. Electr. Eng. Natl. Inst. Technol. ROURKELA, 2014.
- [22] B. S. Kumar, I. I. V Oltage, and D. I. P. S. A. Nd, “Compensation of Voltage Sags and Swells during Abnormal Conditions in Distribution Systems by Dynamic Voltage Restorer (DVR),” vol. 4, no. 4, pp. 62–68, 2014.
- [23] P. Kaur and S. Gupta, “Mitigation Technique For Voltage Sag & Swell By Using Dynamic Voltage Restorer,” Int. J. Innov. Res. Electr., vol. 2, no. 1, pp. 2321–5526, 2014, [Online]. Available: www.ijireeice.com
- [24] M. Islam, N. Raju, and A. Ahmed, “Sinusoidal PWM Signal Generation Technique for Three Phase Voltage Source Inverter with Analog Circuit & Simulation of PWM Inverter for Standalone Load & Micro,” Int. J. Renew. Energy Res., vol. 3, no. 3, pp. 647–658, 2013, [Online]. Available: <http://www.ijrer.net/index.php/ijrer/article/view/771>
- [25] K. Sandhya, “Design of Unified Power Quality Conditioner (UPQC) for

Power Quality Improvement in Distribution System,” IOSR J. Electr. Electron. Eng., vol. 4, no. 2, pp. 52–57, 2013, doi: 10.9790/1676-0425257.

[26] M. Kubeitari, A. Alhusayn, and M. Alnahar, “Space Vector PWM Simulation for Three Phase DC/AC Inverter,” Int. J. Electr. Comput. Eng., vol. 6, no. 12, pp. 1402–1407, 2012.

[27] M. Elamin and E. Ahmed, “Design of a Distribution Transformer Monitoring System using Global System Mobile Technology,” 2017.

[28] S. RATANAPANACHOTE, “APPLICATIONS OF AN ELECTRONIC TRANSFORMER IN A POWER DISTRIBUTION SYSTEM,” no. August, 2004.

[29] F. Ruiz et al., “Dry-type transformers,” TRANSFORMERS, vol. 1, no. power, p. 2, 1998.

[30] A. Borgaonkar, “Solid State Transformers: A Review of Technology and Applications,” no. November, 2015, doi: 10.13140/RG.2.1.1491.1443.

[31] J. Sanguinetti, “Evaluation of Highly Efficient Distribution Transformer Design and Energy Standards Based on Load,” 2012.

[32] S. P. Bhattacharyya, “Shankar P. Bhattacharyya,” no. May, 2016.

[33] T. SHAHI and K. P. SINGH, “Mitigation of Voltage Sags/Swells to Enhance Power Quality of Distribution System Using a Custom Power Device (DVR),” Int. J. Adv. Res. Electr. Electron.

Instrum. Eng., vol. 3, no. 7, pp. 10686–10694, 2014, doi: 10.15662/ijareeie.2014.0307057.

[34] K. Sridevi and P. S. Raju, “Power Quality Improvement on Dynamic Voltage Restorer for Mitigation of Voltage Sag,” vol. 2, no. 12, pp. 1166–1171, 2013.

[35] S. P. Mishra, L. Varghese, J. P. Roselyn, and D. Devaraj, “Mitigation of voltage sags and swells by dynamic voltage restorer,” Adv. Mater. Res., vol. 768, pp. 338–343, 2013, doi: 10.4028/www.scientific.net/AMR.768.338

[36] V. U. Reddy and S. D. Chowdary, “Detection And Mitigation Of Power Quality Disturbances Using DWT Technique And DVR,” vol. 2, no. 6, pp. 766–771, 2012.

[37] C. H. Srisailam and A. Sreenivas, “Mitigation Of Voltage Sags / Swells By Dynamic Voltage Restorer Using Pi And Fuzzy Logic Controller,” vol. 2, no. 4, pp. 1733–1737, 2012.

[38] T. B. Aziz Boukadoum, “Fuzzy Logic Controlled Shunt Active Power Filter for Harmonic Compensation and Power Quality Improvement,” vol. 7, no. 4, pp. 143–149, 2014.

[39] K. P., “Design and Implementation of Shunt Active Power Line Conditioner using Novel Control Strategies Karuppanan. P,” no. August, 2012.

[40] M. F. Arman, “An ‘ Active ’ Passive - Filter Topology for Low Power DC / AC Inverters By,” 2011.